Certificate No: MI/BB//2013/CR-182 **MI. Ref. No:** MI-VAD-CMF-169

FIRE SAFE TEST CERTIFICATE

This certificate is issued to

CAMTECH MANUFACTURING FZCO
Jebel Ali Free Zone,
Dubai,
United Arab Emirates.

to certify that at their request the undersigned surveyor to Intertek-Moody attended their works at Jebel Ali Free Zone, Dubai. on 11th June, 2014, for the purpose of witness of fire safe test of Gate valves. The scopes of Inspection & Approval are as bellow.

STANDARD SPECIFICATION	**: BS EN ISO 10497 : 2010**
TECHNICAL SPECIFICATION	
Design Standard	**: API 600**
Construction	**: Gate Valve**
Size	**: 08" (DN 200)**
Class	**: 1500#**
Valve Serial No.	**: GA0815-RRG-GA0409**
Valve Drg. No.	**: GABB1508FSC01 REV-00.**
MATERIAL OF CONSTRUCTION	
Body	**: ASTM A 216 WCB**
Wedge	**: ASTM A 351 CF8M + ST6**
Stem	**: ASTM A 182 F316**
Seat Ring	**: ASTM A 182 F316 + ST6**
Seals / Gasket	**: SPW SS 316 + Graphite**

Conclusion: Gate Valve Sr. no. GA0815-RRG-GA0409 punched on flange had successfully passed fire safe test as per procedure outlined in BS EN ISO 10497 : 2010, and witnessed by undersigned Intertek-Moody International- Surveyor on June 11th 2014. Temperature report, Test report, Calibration certificates of temp indicators with thermo couples ,Pressure gauge and other calculation sheets are enclosed herewith after endorsement by us.

Intertek-Moody, is to be notified of any changes in design of this valve that may affect the validity of this certificate.

Other Sizes Qualified : 8" and Larger
Other Pressure Class Qualified : Class 1500 ; 2500, PN 260; 420
Date of Issue: 11th June, 2014

Intertek
Reviewed
Witnessed
Initial:
Date:
0015

Issued at:
Vadodara **11.06.2014.** **B.BHAGIRATHKUMAR**

Place **Date** **Manager(Inspection)**

Intertek India Pvt.Ltd.
611, Siddharth Complex,
R.C.Dutt Road.,Alkapuri
Vadodara - 390007(Gui.).India